



Bestermofrigo d.o.o

24 400 Senta

Zaboš Jožef 8

Tel.: +381/24/817-104

+381/63/11-20-325

+381/63/89-45-270

e-mail: frigo@sksyu.net

web : www.bes.rs

MODEL UREDJAJA		BES 8 WW	BES12 WW	BES15 WW	BES18 WW	BES22 WW	BES26 WW	BES35 WW
Kapacitet	Hladjenje ⁽¹⁾ (kW)	6.4	9.1	10.9	13.6	16.4	19	27.8
	Grejanje ⁽²⁾ (kW)	8.76	12.15	16.4	19.9	23.8	29	41
	Grejanje ⁽³⁾ (kW)	8.22	11.3	15.3	18.7	22.5	28	39
	Grejanje ⁽⁴⁾ (kW)	7.1	10.4	14.4	17.7	21.3	26.3	36
Energetska efikasnost ⁽¹⁾ E.E.R.		4	4	3.4	4	4	3.8	4
Energetska efikasnost ⁽²⁾ C.O.P.		7	6.7	6.6	6.5	6.6	6	6.3
Napajanje (V)		380	380	380	380	380	380	380
Ulazna snaga	Hladjenje ⁽¹⁾ (kW)	1.6	1.55	3.2	3.4	4.1	5	6.95
	Grejanje ⁽²⁾ (kW)	1.24	1.81	2.48	3	3.6	4.8	6.5
	Grejanje ⁽³⁾ (kW)	1.47	2.13	2.97	3.52	4.41	4.82	7.5
	Grejanje ⁽⁴⁾ (kW)	1.65	2.6	3.94	4.41	5.28	6.92	8.57
Jačina struje prilikom pokretanja uredjaja (A)		16	16	16	16	25	25	32
Nominalna jačina struje ⁽²⁾		3	4	6.3	8.2	9.5	14	18
Max. temperature grejanja (°C)		65	65	65	65	65	65	65
Min. temperature hladjenja (°C)		7	7	7	7	7	7	7
Temperatura radne sredine uredjaja (°C)	Min.	5	5	5	5	5	5	5
	Max.	45	45	45	45	45	45	45
Nom. protok medijuma u uredjaju								
Primar	m ³ /h	2.1	3.5	3.5	3.5	4	5	6
Sekundar	m ³ /h	1.5	2	2.5	3	3.5	4	5.5
Buka(zvučni pritisak) (dB)		35	35	35	35	35	35	35
Dimenzije uredjaja (ŠxDxV) mm		700x365x 960	700x365x 960	700x365x 960	700x365x 960	700x365x 960	700x365x 960	700x365x 960
Neto težina (kg)		80	85	90	95	100	110	112
Tip izmenjivača (Alfa Laval)	Primar	Pločasti	Pločasti	Pločasti	Pločasti	Pločasti	Pločasti	Pločasti
	Sekundar	Pločasti	Pločasti	Pločasti	Pločasti	Pločasti	Pločasti	Pločasti
Kompresor (Scroll)		Copelland	Copelland	Copelland	Copelland	Copelland	Copelland	Copelland
Cevni priključci	Primar	2x1"	2x1"	2x1"	2x1"	2x1"	2x1"	2x5/4"
	Sekundar	2x1"	2x1"	2x1"	2x1"	2x1"	2x1"	2x5/4"
Rashladno sredstvo	Tip	HFC	R407c	R407c	R407c	R407c	R407c	R407c
	Količina punjenja(kg)		1.6	1.6	2.5	2.5	2.8	2.8
Ugradjena cirkulaciona pumpa		HST/ Grundfos	HST/ Grundfos	HST/ Grundfos	HST/ Grundfos	HST/ Grundfos	HST/ Grundfos	HST/ Grundfos

Uslovi testiranja : temperatura izvora 10 °C W – temperature vode u sistemu (°C)

(1) W7

(2) W35

(3) W45

(4) W55